

CORRIGENDUM -1

Date: 10.11.2020

Tender Notice No. : HITES/FM/JIP/FIRE/2020-21/003 Dated: 23.10.2020

Tender for : “Supplying of ABC, CO2, Foam and MRI compatible Co2 & Water Mist type Fire Extinguisher at JIPMER, Puducherry”.

This is for information of all the bidders that following correction and addition incorporated in the above tender

1. There is a typographical error in the **Vol I NIT, Section I, Page number 6**, Last Date and Time of submission of Bid document wrongly typed.

Particulars	Typographical Error	Corrected
Last Date and Time of submission of Bid document	3.00 PM on 30.09.2020	3.00 PM on 20.11.2020
Date of opening Technical bid document	3.30 PM on 30.09.2020	3.30 PM on 20.11.2020

2. **Approved make list added** in the Vol 4 Technical Specification.

List of Approved Makes of Materials

S.No	Details of equipment/ material	Make / Manufacturer
1.	Trolley mounted Mechanical Foam type Fire extinguisher: capacity 50 ltr	Safex, Safety First, Minimax
2.	ABC trolley mounted Stored Pressure Type Fire extinguisher capacity 50 kg	Safex, Safety First, Minimax
3.	Carbon-dioxide type Fire extinguisher capacity 4.5 Kg	Safex, Safety First, Minimax
4.	ABC type Fire Extinguisher capacity 6 Kg	Safex, Safety First, Minimax
5.	MRI compatible Co2 fire extinguisher capacity 4.5 Kg	Amerex, Cease fire
6.	MRI compatible De -Ionized water mist fire extinguisher capacity of 6 lts	Amerex

The bidders are advised to take into account the Corrigendum before submission of their bids against this tender. If any bidder has already submitted his/her bid, then he/she should resubmit his/her bids taking into account the above Corrigendum.

Sd/-

**Dy. Vice President
Facility Management Division
For and behalf of HITES**