

M/s HLL Infra Tech Services Ltd. (HITES)
(Subsidiary of HLL Lifecare Ltd, A Government of India Enterprise)
As Executing Agency of
Ministry of Health & Family Welfare Government of India

HITES/IDN/AIIMS- REWARI/2023-24/

24.11.2023

AMENDMENT-03

Name of the work: Design, Engineering, Procurement and Construction (EPC) including Operation & Maintenance of All India Institute of Medical Sciences at Rewari (Haryana), INDIA.

Ref: Tender No. HITES/AIIMS-REWARI/EPC/R/2023

The Amendment shall be treated as part of e-tender to be uploaded online duly signed and stamped along with e-tender:

Amendment to Existing e-Tender Clauses:

Sr. No.	Reference to the Tender Document	Existing Clause/Tender Provision	Amended clause/Provision
1.	Vol. -4, DBR, Design Basis Report- Civil Works –Door & Windows	Sliding Aluminium Windows in Residential Quarters & Hostel Buildings	Sliding Aluminium Windows : Height of Aluminium Sliding Windows (DW1) facing towards Balcony areas as shown in the Tender Drawings of all Residential Quarters (except Type-V, Type-VI & Director Bungalow) & all Types of Hostels shall be from sill level (+750mm) up to bottom of Lintel Level as per CPWD Specifications' complete in all respect as directed by Engineer-in Charge.
2.	Vol. -4, DBR, Design Basis Report- HVAC	Duct Insulation:	Duct Insulation: All Duct with Insulation inside the building shall be provided with factory made Aluminium metalized surface. Nothing extra shall be paid on this account.
3.	Vol. -4, DBR, Design Basis Report- Integrated Building Management System	BMS.	Common Command Centre consisting of BMS Room shall be placed in Ground Floor of Hospital building. Nothing extra shall be paid on this account.

Sr. No.	Reference to the Tender Document	Existing Clause/Tender Provision	Amended clause/Provision
4.	Vol. -4, DBR, Design Basis Report-Plumbing (Water Supply and Sanitary Installation, SI No 9 : Tube-well/Bore well Pump and Pumping System)	9. Tube-well/Bore well Pump and Pumping System	<p>9. Tube-well/Bore well Pump and Pumping System Add</p> <p>All Borewells shall be interconnected with each other with minimum 150 dia Ductile Iron class K-9 pipes conforming to IS 8329.</p> <p>The connecting supply lines from Bore wells to interconnection lines & UG Tanks to be designed with ductile iron class K-9 pipes of different diameters with push on joints, as per design requirements. All the operational valves/fittings also designed with same D.I. Specials of class K-12 as per I.S 9523 material as per IS Code and shall be fixed in clay bricks masonry chambers as per specification.</p> <p>All Bore wells shall be operated through manual & auto mode system. Nothing extra shall be paid on this account.</p>
5.	Vol. -4, DBR, Design Basis Report-Plumbing (7. Storm Water Drainage System)	<p>7. Storm Water Drainage System</p> <p>7.1 Planning of Storm Water Drainage System</p> <ul style="list-style-type: none"> The network of storm water system shall be mostly catch basins and RCC pipe network, rain water harvesting pits, as per requirements. 	<p>7. Storm Water Drainage System</p> <p>7.1 Planning of Storm Water Drainage System</p> <ul style="list-style-type: none"> The network of storm water system shall be developed mostly Catch Basins and RCC pipe network as per requirements for the entire campus and rain water harvesting pits as per tender drawing. Nothing extra shall be paid on this account.
6.	Vol. -6, Tender Drawings	Tender Drawings	<p>Tender Drawings:</p> <p>The Quantities mentioned in the Tender Drawings for all External Services viz. Drainage, Sewerage & Water Supply etc. is tentative and for guidance purpose. The mentioned quantities are only indicative & not exhaustive.</p> <p>The EPC Contractor shall carry out Design, Engineering, Supply, Installation, Testing & Commissioning for works in general conform to</p>

Sr. No.	Reference to the Tender Document	Existing Clause/Tender Provision	Amended clause/Provision
			the Latest CPWD Norms, NBC norms, Local bye Laws & statutory norms. Nothing extra shall be paid on this account.

Important Note:

1. The above Corrigendum shall form part of the Tender Document and is to be submitted duly signed by the applicants along with their Application.
2. All other terms & condition of Tender document remains unchanged.
3. Prospective bidders are advised to regularly scan through CPP Portal, HITES website for corrigendum/amendments etc. and separate advertisement will not be made for this.

Vice President (ID)
HLL Infra Tech Services Ltd. (HITES)

END OF AMENDMENT--03